

# AUTOMATIC FIRE EXTINGUISHING SYSTEM for TUNNEL PROTECTION with SPREAD REMOTE CONTROLLED MONITORS (TUDEM-LEGIO)

#### **Generals**

Innovating fire extinguishing system for tunnel fires, for fully automatic intervention or for remote operation from a remote Control Room.

The system is based on the proven technology of fire fighting remote controlled foam/water monitors, worldwide utilized and appreciated for the fire protection in heavy risk plants.



The fire extinguishing system for tunnel protection with remote controlled distributed fixed monitors consists of intervention and control stations with monitors directly installed and uniformly spaced along the tunnel at regular intervals of 42 m.

The intervention and control stations consist of the electric remote controlled monitor with flow rate 1.000 lt./min. with on-off valve, the electric panel, the infrared flame detectors and two IP / TV cameras for visible and infrared light.

The intervention and control stations are interconnected by:

- the main water (or foam premix) supply pipe (working pressure ~10 bar),
- the main electric power supply line,
- the serial bus for data transmission,
- the heat sensing cable for fire detection.



Commands are transmitted independently to each monitor by means of a common serial bus, through a special cable providing also electric power supply of the units.

The fire protection system is integrated with a water pressurizing unit and with a foam proportioning system, consisting of a pumping station (normally with electric pump and Diesel motor pump) and a displacement liquid foam proportioner.

Alternatively to the displacement liquid foam proportioning unit, a balance pressure foam proportioner with related foam concentrate pump can be used.

The dimensioning of the foam storage and proportioning system depends on tunnel length and features. Usually the same foam supply system can be used for the 2 barrel vaults of the tunnel or for 2 adjacent tunnels.



It is important to consider that the extinguishing system with fire hydrant cabinets as required by law can be easily integrated in the proposed automatic extinguishing system with remote controlled monitors.

The fire hydrant cabinets are directly connected to the monitors main water supply line with regular intervals of 126 or 252 meters (with a step multiple of the distance of the intervention and control stations) and are usually equipped with a pressure reducing valve to reduce the water pressure at the manually operated branch pipes at about 4.5 bar.


In this case the pumping station is additionally equipped with a jockey pump to maintain the main water supply line permanently at a pressure of 5 bar for the hydrant cabinets.

## Automatic operation of the system

The automatic operation of the system is performed through a centralized main command and control panel installed in the Control Room of the tunnel or in any other technical room. For the automatic intervention, the extinguishing system is combined with a double technology fire detection system with linear heat detectors and infrared flame detectors installed along the whole length of the tunnel.

In case of detection of a fire, the system automatically selects the two monitors closest (upstream and downstream) to the fire and alarm zone and automatically aims the jet of the monitor on the fire.

The 2 monitors start spraying water or foam with a step-less adjustable jet from full jet (for maximum throw and extinguishing power) to narrow cone and wide cone fog jet (for maximum cooling effect) as shown on the top of page 5.



Typical procedure operating system

DIS NR MT001758





At the same time, if required, the two monitors positioned immediately upstream and downstream the 2 units involved in the fire extinguishing intervention start spraying water with a wide cone fog jet (with spray angle 120°) with cooling effect to drop the temperature inside the tunnel and for containing the fire smoke.

The whole typical process is reported in the scheme on page 3.

#### Manual remote control of the system with joy-sticks from the panel in the Control Room

From the main command and control panel in the Control Room it is possible to control the situation in the tunnel by means of high sensibility IP / TV cameras for visible and infrared light mounted in the intervention and control stations, and to operate the monitors from remote with the joy-stick controller, aiming the jet of the monitors exactly on the fire.

uDEM : Sistema Automatico di Speg	nimento per Gallerie [ v2.0.0.219	31)/it-IT/it-IT] + (C) Caccialanza & C.,	5PA					
stema 👻 Pianta Generale 🛛 Pianta	a Circuito Pianta Comunicazion	e Pianta Dettaglio Consolle <i>R</i>	DB-Principale DB-Secon	dario Controllore P	trincipale Controllore Sec	condario Emergenc	y Stop Servizio •	
ale NORD, Stazione 15 172:16:101:111 172:16:101:112	172.16.101.113 172.16.101		11 172.16.102.112 172.16.102	113 172.18.102.114	172:16:102:115 172:16:103:111	172:16:103:112 172:16:10	03.113 172.16.103.114	172.16.103.115
ione 16 => 30 172.16.104.111 172.18.104.112	172.16.104.113 172.16.104	114 172.16.104.115 172.16.105.	111 172.16.105.112 172.16.105	113 172.16.105.114	172.16.105.115 172.16.106.111	172.18.106.112 172.16.1	06.113 172.16.106.114	172.16.106.115
ione 31 => 45 172.16.107.111 172.16.107.112	172.16.107.113 172.16.107	114 172.16.107.115 172.16.108	111 172.16.108.112 172.16.10	113 172.16.108.114	172.16.108.115 172.16.109.111	172.16.109.112 172.16.1	09.113 172.16.109.114	172:16:109:115
ione 46 -> Portale SUD 172.16.110.111 172.16.110.112	172.16.110.113 172.16.11	0.114 172.16.110.115 172.16.1.1	77 M	Dook.#9(17216.102114/CP)		venerdì 21	novembre 2008	13.58.39
13 46 45 debug L detector, state dets. 13 46 50 debug L detector, state dets. 13 46 55 debug L detector, state dets. 13 46 55 debug L detector, state dets. 13 47 15 debug L detector, state dets. 13 47 15 debug L detector, state dets. 14 72 5 debug L detector, state dets. 14 72 5 debug L detector, state dets. 14 74 5 debug L detector, state dets. 14 74 5 debug L detector, state dets. 14 75 debug L detector, state dets. 15 33 debug L detector, state dets. 15 34 debug L detector, state dets. 15 35 35 debug L detector, state dets. 15 35 30 debug L detector, state dets. 15 36 debug L detector, state dets. 15 37 debug L detector, state dets. 15 36 debug L detector, state dets. 15 36 debug L detector, state dets. 15 36 debug L dets. 15 36 debug L detector, state dets. 15 36 debug L detector, state dets. 15 37 debug L detector, state dets. 15 37 debug L detector, state dets. 15 36 debug L detector, state dets. 15 37 debug L detector, state dets. 15 37 debug L dets. 15 36 37 debug L	stamp changed (2008-10.02 (± 14, 15, 19), stamp changed (2008-10.02 (± 1	#356 #355 #355 #355 #355 #355 #355 #355	2	93 : Thermo-Melder 3 auf CP	3 4 5 6   Off Off Off Off Off   Off Off Off Off Off   Disabled J. (0 m/J, (0 m/V) Bf >> [ Disabled J. (0 m/A]. (0 m/V] Bf >> [ Disabled J. (0 m/A]. (0 m/V]   Bf >> [ Disabled J. (0 m/A]. (0 m/V] Bf >> [ Disabled J. (0 m/A]. (0 m/V]	96 : IR-Melder 6 CP # 97 : Temperatur-Meld	11 12 13   Off Off Off Off   Off Off Off Off Off   auf CP #9 ⇒> [Disabled], [0 mA] OmA], [0 mA] OmA] OmA] OmA]   19 ⇒> [Disabled], [0 mA] OmA] OmA] OmA] OmA] OmA]   er 7 auf CP #9 ⇒> [Disabled], [0 inable] Off Off Off Off Off	) mA], [() mV]
ione 8 / 172 16:102 113 / CP-8	en 1 - FC Abn	Stazione 9 / 172.16.102.114 / CP-9 FC- Sinistra ugello moritore	Destra elevazion	Sinistra	FC- Destra	FC-Alto FC- Sinistra	rotazione monitore	FC- estra
eta geto discritto di constructo di construc	getto frazionatFC-Basso	getto getto stretto valvola on off	getto frazionat. FCBasso	getto getto getto getto	getto frazionat 2008-11-1918.23.52 posit: mon. stan posit: mon. stan STOP mon	dard sud valvola on		petto zionat. FC.B. posiz mon. standard m posiz mon. standard s STOP monitore
/Guas C2/Guas 230V/ok 23	307/Gu 247/ok 247/Gu	C1/Stör. C2/Stör. 230V/ok	230V/5tič 24V/ok 24V/5tič	C1/Stór. C2/Stór.	2307/ok 2307/5tö 247/ok	24V/Stor C1/Stor C2/St	ж. 230V/ok 230V/Sti	i 24V/ok 24V/S

This operation can be performed as final tuning of the automatic intervention of the system or on autonomous decision of the operator in the Control Room.



In this case it is sufficient to click with the mouse the exact point on the screen where the extinguishing operation is required in order to activate immediately the automatic selection procedure of the 2 monitors to be activated for extinguishing operation and of the 2 monitors to be activated for extinguishing operation.

The IP / TV cameras for visible and infrared light mounted in the intervention and control stations allow the monitoring of the tunnel from the Control Room, with visible light or infrared technology depending on the local conditions and on the size of the objects to be observed.



Finally the system allows to best coordinate the operations of the fire brigades, showing continuously the situation of the fire area and of the surrounding.

## **Dimensioning of the system**

Studies on the behaviour of fire development in tunnels performed by Research Institutes and Fire Brigades Laboratories are available in the literature, both supported by real tests and by mathematical models based on semi-empiric relations.

These studies, specially focussed on the time / temperature curves depending on the heating power of the different ignition sources, show that the maximum temperatures in a tunnel fire are reached after about 10 minutes, and that for the first 5 minutes the temperature inside the tunnel does not significantly differ from the temperatures reached by similar fires in open space.

When proper extinguishing actions start, the temperature increase stops almost immediately.

Following to the above, for tunnel fires an efficient extinguishing system must be activated in less than 5 minutes.

Of course, above indicated parameters are average values, and the specific value for each single tunnel must be determined with a risk analysis.

The dimensioning of the automatic fire extinguishing system with remote controlled monitors for tunnels protection must consequently assure an intervention time of less than 3 minutes from the start of the fire to the beginning of the automatic extinguishing action.



A time of less than 2 minutes is considered for the fire detection and for the validation procedures, and 1 minute is considered for the monitors to open the valves and to start the extinguishing operation.

As already mentioned, the distance of the monitors along the tunnel is 42 meters.

In case of remote joy-stick operation of the system directly from the operator in the Control Room, the time of intervention can be further reduced.

Indeed, when the operator in the local or remote Control Room individuates a fire, he can immediately activate the extinguishing procedure (eliminating the time of automatic fire detection and validation), starting the extinguishing operation in less than 2 minutes.

The same happens if the operator decides to activate the extinguishing operation based on an alarm from a single fire detector, after checking the situation via the IP / TV cameras for visible and infrared light, without waiting for the redundant signal of the heat sensing cable (which is normally slower).

#### **Structure of the system**

The main water (or foam premix) supply pipe is installed in elevated position at the wall along the tunnel, equipped with the main electric power supply line, the serial bus for data transmission and the heat sensing cable for fire detection.

Both the main electric power supply and the data transmission are carried out with a double loop.

The intervention and control stations are mounted along the tunnel with a typical spacing of 42 m.

The below picture shows the panel installed in each intervention and control station.



These points are the backbone of the fire detection sub-system, with regard both to the flame detectors (2 flame detectors mounted at each intervention and control station, oriented to the 2 directions of the tunnel) and to the heat sensing cable, divided into different functional sections distributed along the tunnel.

The signals of the fire detectors are processed in protected wall-mounted panels installed along the tunnel in each intervention and control station, where additional fixed monitoring cameras, both for visible and infrared light, can be interfaced if required.

The same panels also provide the power supply to the remote controlled monitors and to the related remote controlled on-off valve for start or stop of the water or foam stream.



A2 El monitor with nozzle and on-off valve

The monitors are dimensioned for a specific water / foam flow rate of 1.000 lt./min. each, and following much higher than the total specific flow rate of any mobile unit or fixed spray system normally used for extinguishing operations inside tunnels.

The total water discharge of the remote controlled monitors system is nevertheless similar to the flow rate required for other fixed spray systems for tunnel protection, however this system allows to concentrate the full available water or foam stream exactly where required on the fire, instead of dispersing the extinguishing agent flow rate with uniform distribution along longer sections of the tunnel.


The scheme on page 8 shows the typical water distribution of the system, including also the fire hydrant cabinets as required by law.

The scheme on page 9 shows the typical electric and signal connections with the redundant double loop, to assure 100% functionality of the system in case of first failure in any point of the tunnel.




CACCIALANZA & C. Fire fighting security systems





Typical water distribution of the system

CACCIALANZA & C. Fire fighting security systems



Dwg nr. MT001761

Typical double loop electric power and signal redundant connections diagram

#### <u>Features of the fire extinguishing system for tunnel protection with remote controlled</u> <u>distributed fixed monitors and of the intervention and control stations</u>

The high performances and peculiar features of the fire extinguishing system for tunnel protection with remote controlled distributed fixed monitors and of the intervention and control stations can be summarized as follows:

- compact dimensions for fitting in the available spaces of motorway and railway tunnels,
- possibility to be installed and to work in any position (horizontal, vertical, reclined) in the tunnel vault,
- high reliability of all functions,
- reasonable costs,
- self check and transmission of position identification and working position,
- specific design for operation with water and with foam.

#### System reliability

The world wide proven extinguishing capacity of the automatic fire fighting system with remote controlled monitors is combined with the highest reliability of its components, considering the particular conditions where the fire fighting intervention must be performed. To assure the highest reliability, redundancy has been applied to all critical parts of the system, for which not only the best materials and components available on the market have been selected, but also the most updated and reliable technology of monitoring, communication and check procedures have been adopted.

In particular for the data transmission a TCP/IP system has been selected, in order to allow the direct use of already existing communication structures or future structures to be realized for the remote transmission of alarms, commands and controls to the centralized Control Rooms of the tunnel without additional costs.

The system is therefore designed to be redundant in all its features:

- extinguishing operation by means of 2 monitors on the 2 sides of the fire (1 monitor is sufficient for extinguishing the fire),
- the monitors approach the fire from 2 different sides,
- the power supply of the intervention and control stations is performed in a loop; therefore it is possible to supply separately and independently the 2 sides of any area involved in the fire,
- the data transmission (both via optical fibre and copper cable) is performed in a twin loop, separately and independently for the two sides of any area involved in the fire.

#### **Easy system installation**

The automatic fire extinguishing system for tunnels protection with remote controlled distributed fixed monitors can be easily installed in new or in existing tunnels, without need to stop the tunnel traffic during the installation works of the system.

It can be installed in motorway tunnels, railway tunnels and in underground lines.





#### **Maintenance**

Like all fire protection systems (as required by law), the automatic fire extinguishing system for tunnel protection with remote controlled monitors needs periodical maintenance.

The rules require that <u>all</u> main and peripheral components of a fire protection system are subject to scheduled maintenance and periodical functional tests.

Maintenance activities on the system are particularly easy because:

- all system components are permanently monitored by the central control panel with immediate signalisation and record of any problem,
- -most of the components are mounted in the intervention and control stations, so that the maintenance can be easily carried out without stopping the tunnel traffic.

Finally, no relevant pipe reductions or small size calibrated orifices are provided in the whole system, which items are particularly sensitive to impurities in the fire water and require special accurate maintenance interventions to assure their proper operation.

# Applications of the system for ordinary monitoring and maintenance activities in the tunnel

Beside the main fire protection function, the automatic fire extinguishing system with distributed fixed remote controlled monitors can be utilized also for different purposes, such as monitoring and maintenance activities during the ordinary operation of the tunnel.

The monitors installed along the tunnel can be operated singularly and in the required sequence, and can be oriented continuously and in each direction by means of the remote control according to the requirements of the different operations.

The IP / TV cameras for visible and infrared light installed in the intervention and control station along the tunnel can be used to check traffic and maintenance activities without any extra cost for installation and maintenance of these cameras.

The monitors can be used for cleaning activities (washing of the internal tunnel surfaces) or anti-pollution activities (dilution of dangerous liquids spills) wherever required along the tunnel, moving them by means of the remote control system and spraying specific detergent or solvent liquids properly admixed to the water.

The intervention and control stations can be equipped with sensors for check of the air pollution (CO, etc.) or for check of explosive atmospheres in the tunnel , for continuous working and monitoring both during ordinary traffic conditions and in emergency conditions.

The pictures in the tunnel show the extinguishing tests performed in the Test Tunnel of the Italian Fire Brigades' Training Centre in Montelibretti (Roma).

Caccialanza & C. reserve the right to change at any time, without prior notice, any specification or feature of the system in order to continuously improve the product.

The Automatic Extinguishing System for Tunnels with Remote Controlled Monitors on Overhead Rail is protected by the following Patents: Italian Patent MI2007A 000584 and MI2008A 000735, International Patent PCT/EP2008/002153.